



July 11, 2006.

Jay Strother
Muller, Sullivan & Sheehan
98 Clarke Street
Jamestown, RI. 02835
Via fax: 508-584-3576

RE: Roof Ridge Venting

Dear Jay:

This letter is in follow-up to our recent phone conversations concerning EcoStar roof installations with a non-vented ridge condition. Please be advised that projects with a non-vented ridge are eligible for Gold Star warranty coverage. However, any damage done to the roof sheathing due to the non-vented ridge condition that adversely affects the installation or appearance of the EcoStar roof assembly will not be covered under the terms of the warranty.

Please feel free to contact me if I may be of any further assistance in this matter.

Sincerely,

Brian Heister
Manager- Technical & Warranty Services
EcoStar
Division of Carlisle Syntec Inc.